

# National Grid 2022 March Local Transmission Plan Update

March 24, 2022 NYISO ESPWG

nationalgrid



# National Grid March 24, 2022

## Local Transmission Plan Update

Region	In-Service Date	Firm Project	Comment
Frontier	8/2022	Reconductor/Reconfigure 4 spans of Lockport/Mortimer 103/104	Results in swap of Lines 103 and 104 positions at Lockport.
Frontier	1/2023	Install R264 at Lockport for Line 108 and operate as alternate breaker for Line 108 at Lockport	East bus alternate to West bus termination and new operating procedure due to generator deactivation.

**This is an incremental update to the Nov 2021 LTP as a result of the 2022 Q1 STAR**

# National Grid LTP

**Interested parties may submit written comments on National Grid’s LTP within 30 days (April 24, 2022) to:**

Mark Domino PE, Engineering Manager

Transmission Planning - NY

National Grid

300 Erie Blvd, West

Syracuse, NY 13202

- [TransmissionPlanning@nationalgrid.com](mailto:TransmissionPlanning@nationalgrid.com)

**This LTP will be posted on the National Grid OASIS website:**

<https://www9.nationalgridus.com/oasis/>

**TGP-28 – Transmission Planning Guide - may be found at:**

[https://www9.nationalgridus.com/oasis/non\\_html/TGP28%20Issue%205%20Jan%2027%202020.pdf](https://www9.nationalgridus.com/oasis/non_html/TGP28%20Issue%205%20Jan%2027%202020.pdf)

| [Local Transmission Plan] | [2022 March 18]

national**grid**