

**National Grid's
TRC/BC Screening Reference Document for
Commercial & Industrial Projects**
(revised 09/11/13)

**Developed based on New York State Public Service
Commission Regulatory Guidelines for Screening Energy
Efficiency Projects**

Table of Contents

	Page
Step 1 - Screening Methodology	3
Step 2 – Screening Method Examples	6
• Retrofit Screen Shots and Report	
• Normal Screen Shots and Report	
• Early Screen Shots and Report	
• Add - On Screen Shots and Report	
• Special Screen Shots and Report (Future)	
Step 3 – Deliverables	16
• BC Screening Report	
• .csv File Upload	
• EEM Breakout Spreadsheet	
Step 4 – EEM Breakout	17
Gas Screening Tool	18

Please note: PROGRAMS CAN CHANGE WITHOUT NOTICE!

For additional Program Details please visit our website at:
<https://www1.nationalgridus.com/energysolutionspartner>

Step 1 – Screening Methodologies

The New York Public Service Commission has set guidelines for the NYS utilities to follow to make sure measures and projects implemented by customers are cost effective prior to committing funding to those projects. The Benefit Cost (BC) Screening tool is developed to screen Custom energy efficiency projects to determine if a project is eligible to receive incentives from National Grid.

The tool uses a series of calculations that include:

- 1) LRAC – Long Range Avoided Cost, to avoid the cost associated with new energy production and distribution.
- 2) Societal Benefits
- 3) Simple Payback

The end result of the EEM passes the BC Screening requires that the EEM (Energy Efficiency Measure) screens at a “1” or greater also known as a BC of 1, in order for the project to receive an incentive.

Recently the NYS PSC changed the way that we screen projects by changing the method that you will choose to screen an EEM. The items 1 – 4 below are a brief explanation of the screening methods and their intended use. It is important that the appropriate method is selected when analyzing various projects. As a result, it is important to be familiar with the various screening methods.

TIP 1 – The BC screening tool <Help> tab is very useful for explanations of the inputs required.

BC Screening Method for Custom Projects

1) BC Screening Method: Retrofit

- THIS METHOD APPLIES ONLY TO LIGHTING MEASURES.
- Uses full values of savings and project costs on lighting and lighting related measures. Lighting controls apply when the lighting controls savings is < then 5% of total lighting project savings. In the case where lighting controls exceed 5% of the project savings – a different method called “Add-On” needs to be used. (See # 3 below).
- Operating hours, lighting type, application (outdoor or indoor) and calculated lighting measure life is utilized for screening

TIP 2 – In order for LED lighting to qualify for an incentive, it has to be listed on the DLC's or Energy Star's most current lists. The NYS PSC has set LED rules for determining the Effective Useful Life (EUL) of LED lighting. The lighting EUL is impacted by ambient temperature that they are installed in. Therefore, the EUL is 50,000 hours exterior, 35,000 hours interior, NG Approved but unlisted is 25,000 hours and all other lighting is 70,000 hours. Being considerate of the LED EUL impact a project consideration could be to use a weighted average (EUL) measure life. (See internal memo from TC on the DLC decision for LEDs).

2) BC Screening Method: Early Replacement

- THIS METHOD APPLIES TO NON-LIGHTING RELATED MEASURES.
- This method should be used for replacement of equipment before it reaches end of its Effective Useful Life (EUL).
- Projects will follow the Tech Manual Appendix M methodology incorporating Dual Baseline Method of analysis.
- If one cannot document or substantiate the age of the equipment in place is less than its prescribed EUL, the replacement must be analyzed as normal / end of life replacement (See #4 below).

3) BC Screening Method: Add-On

- Add-ons would be enhancing performance of existing equipment by adding devices such as VFD, lighting controls (> 5% savings, see bullet 2, retrofit above), compressed air storage tanks, EMS, etc.

4) BC Screening Method: Normal [Formerly Time of Replacement (TOR)]

- THIS METHOD IS APPLIES WHEN THE AGE OF THE EQUIPMENT BEING REPLACED IS PAST ITS EUL.
- Analysis uses code referenced design criteria or industry standard equipment as baseline. A code example is the 2010 Energy Conservation construction code of New York, if applicable.
- Required will be the cost and energy usage of Code standard equipment to be used for the baseline for screening.
- Required cost and energy usage of proposed equipment to be used as EE (proposed) equipment for screening.

TIP 3: The electric screening tool will automatically calculate the program caps when you select electric program option D2 and Normal Replacement. The BC screening tool will set the incentive at 75% of the incremental not to exceed 50% of the total project/EEM cost where the project cost is the labor and materials for the new high efficiency equipment. All other caps are in place: \$/kWh, \$/therm, buy down to 1 year payback for commercial /6 month payback for industrial customers or 50% of the total project cost , whichever is the least amount.

Please note: The tool calculates 75% of incremental costs as the incentive as long as all other caps are met. However, National Grid is paying 100% of incremental costs as long as it does not exceed 50% of the total project cost.

5) BC Screening Method: Special Circumstances

- THIS METHOD APPLIES ONLY TO COMMERCIAL AND INDUSTRIAL MACHINERY AND MULTI-FAMILY CENTRAL SYSTEMS BUT NOT TO LIGHTING EQUIPMENT.
- Customers typically influenced by initial capital outlay more than life cycle economics due to lack of capital.
- Customers with short time horizons and other factors which tend to prevent long range economic decision making with regard to the installation of high efficiency equipment.

Special Circumstances must follow this five criteria regarding equipment being considered for replacement:

1. Equipment age equals or exceeds 125% of its effective useful life (EUL) and energy consumption significantly exceeds that of current high efficiency models by at least 20%.
2. There is a history of significant repairs or replacement with used equipment
3. The prospective next repair or replacement is likely to be initially much less expensive than replacement with new high efficiency machinery.
4. Documentation to support above criteria must be collected and attached to the application in InDemand.
5. Equipment fitting these criteria would be subject to a form of dual baseline TRC screening. Initial baseline of 25% of new measure's prescribed EUL. Second baseline consists of 75% remainder based on minimally code compliant or standard efficiency equipment. Under this approach, first year savings would be reported as the difference between the existing equipment's electric usage and that of the high efficiency equipment which replaces it. Analysis will require use of tables published by PSC under Appendix N to the NY Tech Manual.

Step 2 – Screening Method Examples

Now that all the screening methods have been explained, it is important to look at an example of each method for an actual project to show the inputs required for each method. Each sample screening snapshot has a project description, summary and the following page is the report that is automatically generated saved as an .html file on your C drive. The other automatic output is a .csv file. The .csv file is an excel spreadsheet that is used to automatically uploads the screening data to our tracking software known as InDemand. Step 3 explains the report and .csv files in more detail.

See pages 8 - 15

Custom Screening Example #1: Retrofit (Lighting Project)

Energy Efficiency Measure:

- Replace qty 50 - 440w MH with 4 lamp T-5, 50 – 40W Halogen with 17W LED, 10 - 400w HPS wallpacks with 40w LED wallpack & 10 – 150w Halogen Floods with 45w LED Flood

Customer Name	Retrofit Lighting Example		Utility Contact						
Project Description	LED and T-5 System Upgrade		Phone Number						
Existing Condition	50 - 440w MH, 50 – 40W Halogen, 10 - 400w HPS wallpacks, 10 – 150w Halogen Floods		Proposed Description	4 lamp T-5, 17W LED, 40w LED wallpack 45w LED Flood					
Program	EI	TRC	Retrofit	State	NY	Classification	Industrial (< 2 MW)	App No	Example #1
Measure	LGHT	Measure Life	Retrofit	Measure Description	Lighting Systems				
		Peak kW usage	Early		Costs		Non-Electric Benefits		
Existing Equipment	27.40	145000	Special	EE Equip. Cost	10000	Oil (gallons)	0		
EE Equipment	12.6	62906	AddOn	EE Labor Cost	2000	Gas Heating (therms)	0		
Full Savings	14.8	82094		EE Total Cost	12000	Gas Non-Heat. (therms)	0		
Average Cost/kWh		0.1				Water (gallons)	0		
Est. Annual Cost Savings(\$)		8209.4				Waste Water (gallons)	0		
%On Peak kWh Saved		100				Other (\$)	0		
Calculated Incentive		6000	Authorized Incentive		6000	50% of Project Cost			

Summary:

- Project: Lighting upgrade – EEM: T-5 & LED Lighting
- Energy Analysis and Findings:
 - 82,094 kWh saved and 14.8kW (June, July and August)
 - \$8,209 saved per year at \$0.10/kWh
- Project Costs - \$12,000 Energy Efficient
- Incentive - \$6,000 Incentive
 - Incentive is 50% of the incremental cost as the simple payback is brought down to 0.7 years.

National Grid 2013 Custom Screening Tool Upstate NY - v 1.0 Report Version - 1.0

Customer Name: Retrofit Lighting Example
 Project Description: LED and T-5 System Upgrade
 Existing Case 50 - 440w MH, 50 - 40W Halogen, 10 - 400w HPS wallpacks, 10 - 150w Halogen Floods
 Proposed Case 4 lamp T-5, 17W LED, 40w LED wallpack 45w LED Flood

Utility Contact: Phone Number:
 Program: EI App Number: Example #1
 State: NY Classification: Industrial (< 2 MW)

Time Period	Energy (kWh) Reduction Per Period	Hours Per Period	Average Demand Reduction Per Period
Winter			
December	0	0	0
January	0	0	0
February	0	0	0
Summer			
June	0	0	14.8
July	0	0	14.8
August	0	0	14.8
September	0	0	0

Measure Code: LGHT	TRC Method: Retrofit	Existing Age: 0	RUL	NA
Measure Description: Lighting Systems	DFP: NA	Incr/Full kWh: NA	A djEUL	NA
Measure Life: 11	Ben Adj: NA	Incr/Full Cost: NA	Cost Adj	NA
Est Equip Costs: \$10,000	Oil (Gallons): 0	WasteWater (Gallons): 0		
Est Labor Costs: \$2,000	Gas Heating (Therms): 0	Water (Gallons): 0		
Est Total Cost: \$12,000	Gas NonHeating (Therms): 0	Other (\$): \$0.0		
Existing Equip Usage: 27.40 KW, 145,000 KWH	Total NEB \$ Savings: \$0.0	Pk Sum kW Rd: 14.8		
Std Equip Usage: NA, NA	kW Years: 183	kW Years (A djEUL): NA		
EE Equip Usage: 12.6, 62,908	Lifetime MWH: 903	Lifetime MWH (A djEUL): NA		
Total Est Annual kWh Savings: 82,094	Payback Without Incentive: 1.5			
Average Cost Per kWh: 0.1	Payback With Proposed Incentive: 0.7			
Est Annual Energy Cost Savings: \$8,209				
% On Peak Energy Savings: 100				
Proposed Incentive: \$8,000				

50% of Project Cost

Customer Cost : \$8,000

Custom Screening Example #2: Normal Replacement (Compressed Air Project)

Energy Efficiency Measure:

- Replace two, 16 year old, 75 hp inlet modulating air compressors with a 200 hp VSD.

Customer Name		Compressed Air Example-Normal		Utility Contact			
Project Description		Two older air compressors are replaced with a 200 hp VSD		Phone Number			
Base Case Description		2 - 75 hp inlet modulating air compressors		Proposed Description		1- 200 hp VSD rotary screw compressor	
Program	D2	TRC	Normal	State	NY	Classification	Industrial (> 2 MW)
Measure	CAIR	Measure Life	15	Measure Description	Compressed Air		
Code/Std Equipment		600	2500000	Base Case Costs		100000	
EE Equipment		560	2250000	Proposed Costs		150000	
Incremental Savings		40	250000	Incremental Costs		50000	
Average Cost/kWh		0.1		Incr Equip. Cost		0	
Est. Annual Cost Savings(\$)		25000		Incr Labor Cost		0	
%On Peak kWh Saved		100		Oil (gallons)		0	
				Gas Heating (therms)		0	
				Gas Non-Heat. (therms)		0	
				Water (gallons)		0	
				Waste Water (gallons)		0	
				Other (\$)		0	
Calculated Incentive		37500		Authorized Incentive		6000	
						0.5 year payback	

Summary:

- Project: Compressed Air System Improvements - EEM: 200 hp two stage VSD compressor
- Energy Analysis and Findings:
 - 250,000 kWh saved and 40 kW (June, July and August)
 - \$25,000 saved per year at \$0.10/kWh
- Project Costs
 - \$100,000 Standard Replacement
 - \$150,000 Energy Efficient
 - \$50,000 Incremental Project Cost
- Incentive
 - \$37,500 Incentive
 - Incentive is 50% of the incremental cost as the simple payback is bought down to 0.5 years.

National Grid 2013 Custom Screening Tool Upstate NY - v 1.0 Report Version - 1.0

Customer Name: Compressed Air Example-Normal
 Project Description: Two older air compressors are replaced with a 200 hp VSD
 Existing Case: 2 - 75 hp inlet modulating air compressors
 Proposed Case: 1- 200 hp VSD rotary screw compressor

Utility Contact: _____ Phone Number: _____
 Program: D2 App Number: Example #2
 State: NY Classification: Industrial (> 2 MW)

Time Period	Energy (kWh) Reduction Per Period	Hours Per Period	Average Demand Reduction Per Period
Winter			
December	0	0	0
January	0	0	0
February	0	0	0
Summer			
June	0	0	40
July	0	0	40
August	0	0	40
September	0	0	0

Measure Code:	CAIR	
Measure Description:	Compressed Air	
Measure Life:	15	
Base Costs	\$100,000	
Proposed Costs	\$150,000	
Est Incremental Costs	\$50,000	
Est Incr Equip Costs	\$0	
Est Incr Labor Costs	\$0	
	KW	KWH
Existing Equip Usage	NA	NA
Std Equip Usage	600	2500000
EE Equip Usage	580	2,250,000
Total Est Annual kWh Savings	250,000	
Average Cost Per kWh	0.1	
Est Annual Energy Cost Savings	\$25,000	
% On Peak Energy Savings	100	
Proposed Incentive	\$37,500	

TRC Method	Normal		
Existing Age	0	RUL	NA
DFF	NA	A DJEUL	NA
Incr/Full kWh	NA	Incr/Full Cost	NA
Ben Adj	NA	Cost Adj	NA
Oil (Gallons)	0	Waste Water (Gallons)	0
Gas Heating (Therms)	0	Water (Gallons)	0
Gas NonHeating (Therms)	0	Other (\$)	\$0.0
Total NEB \$ Savings	\$0.0		
Pk Sum kW Rd	40.0
kW Years	599	kW Years (A DJEUL)	NA
Lifetime MWH	3750	Lifetime MWH (A DJEUL)	NA
Payback Without Incentive	2.0		
Payback With Proposed Incentive	0.5		

0.5 year payback

Customer Cost : \$12,500

Custom Screening Example #3 : Early Replacement (Compressed Air Project)

Energy Efficiency Measure:

- Replace qty 1, 12 year old, 100 hp inlet modulating air compressors with a 100 hp VSD.

Customer Name	Compressed Air Example - Early		Utility Contact		
Project Description	One older air compressor is replaced with a 100 hp VFD		Phone Number		
Existing Condition	1 - 100 hp modulating air compressor	Proposed Description	1- 100 hp VFD compressor		
Program	EI	TRC	Early	State NY	
Classification	Industrial (< 2 MW)		App No Example #3		
Measure	CAIR	Measure Life	15	Measure Description	Compressed Air

	Peak kW usage	kWh usage	Costs	Non-Electric Benefits		
Existing Equipment	248	2172200	Std Cost (Mtl+Labor)	0	Oil (gallons)	0
Code/Std Equipment	248	2072200	EE Equip. Cost	120000	Gas Heating (therms)	0
EE Equipment	204	1787000	EE Labor Cost	20000	Gas Non-Heat. (therms)	0
Incremental Savings	44	285200	EE Total Cost	140000	Water (gallons)	0
Full Savings	44	385200			Waste Water (gallons)	0
Average Cost/kWh		0.1			Other (\$)	0
Est. Annual Cost Savings(\$)		38520				
%On Peak kWh Saved		100				

Existing Equip Age	10	Benefit Adj	1
RUL	5	Cost Adj	1
		Adj EUL	1
Incremental/Full kWh Savings	0.74		
Incremental/Full Cost	1		

Calculated Incentive	70000	Authorized Incentive	6000	50% of Project Cost
----------------------	-------	----------------------	------	---------------------

Summary:

- Project: Compressed Air System Improvements - EEM: 100 hp two VSD compressor
- Energy Analysis and Findings:
 - 385,200 kWhrs saved
 - 44 kW (June, July and August)
 - \$38,520 saved per year at \$0.10/kWhr
- Project Costs
 - \$140,000 Energy Efficient
- Incentive
 - \$70,000 Incentive
 - Incentive is 50% of the incremental cost as the simple payback is bought down to 2 years.

National Grid 2013 Custom Screening Tool Upstate NY - v 1.0 Report Version - 1.0

Customer Name: Compressed Air Example - Early
 Project Description: One older air compressor is replaced with a 100 hp VFD
 Existing Case 1 - 100 hp modulating air compressor
 Proposed Case 1- 100 hp VFD compressor

Utility Contact
 Program: EI Phone Number:
 State: NY App Number: Example #3
 Classification: Industrial (< 2 MW)

Time Period	Energy (kWh) Reduction Per Period	Hours Per Period	Average Demand Reduction Per Period
Winter			
December	0	0	0
January	0	0	0
February	0	0	0
Summer			
June	0	0	44
July	0	0	44
August	0	0	44
September	0	0	0

Measure Code:	CAIR	
Measure Description:	Compressed Air	
Measure Life:	15	
Standard Costs	0	
Est Equip Costs	\$120,000	
Est Labor Costs	\$20,000	
Est Total Cost	\$140,000	
	KW	KWH
Existing Equip Usage	248	2,172,200
Std Equip Usage	248	2,072,200
EE Equip Usage	204	1,787,000
Total Est Annual kWh Savings	385,200	
Average Cost Per kWh	0.1	
Est Annual Energy Cost Savings	\$38,520	
% On Peak Energy Savings	100	
Proposed Incentive	\$70,000	

TRC Method	Early		
Existing Age	10	RUL	5
DFF	4	ADJEUL	1
Incr/Full kWh	0.74	Incr/Full Cost	1
Benefit Adj	1	Cost Adj	1
Oil (Gallons)	0	WasteWater (Gallons)	0
Gas Heating (Therms)	0	Water (Gallons)	0
Gas NonHeating (Therms)	0	Other (\$)	\$0.0
Total NEB \$ Savings	\$0.0		

Pk Sum kW Rd	44.0
kW Years	659	kW Years (AdjEUL)	43.958
Lifetime MWH	5778	Lifetime MWH (AdjEUL)	385.2
Payback Without Incentive	3.6		
Payback With Proposed Incentive	1.8		

50% of Project Cost

Customer Cost : \$70,000

Custom Screening Example #4: Add-On (VSD Project)

Energy Efficiency Measure:

- Add VSDs to a 15 HP supply and 15 HP exhaust fans for a gym/pool facility heating and ventilating unit.

Customer Name		VSD Example - Add-On		Utility Contact			
Project Description		One older air compressor is replaced with a 100 hp VFD		Phone Number			
Existing Condition		HV-3 supply fan (15 hp) and RF-1 return fan (15 hp) at constant speed		Proposed Description		Install VSD's to operate the HV-3 and RF-1 at 80% speed.	
Program	TRC	State	Classification	App No			
EI	AddOn	NY	Commercial (< 2 MW)	Example #4			
Measure	Measure Life	Measure Description					
VSDH	15	Drives on HVAC systems					
Peak kW usage		kWh usage		Costs		Non-Electric Benefits	
Existing Equipment	0	175601	EE Equip. Cost	11117	Oil (gallons)	0	
EE Equipment	0	108647	EE Labor Cost	0	Gas Heating (therms)	0	
Full Savings	0	66954	EE Total Cost	11117	Gas Non-Heat. (therms)	0	
Average Cost/kWh	0.08						
Est. Annual Cost Savings(\$)	5356.32						
%On Peak kWh Saved	100						
Calculated Incentive		Authorized Incentive		50% of Project Cost			
5558.5		6000					

Summary:

- Project: Add VFDs to a 15 HP supply and 15 HP exhaust fans for a pool facility heating and ventilating unit.
- Energy Analysis and Findings:
 - 66,954 kWh saved
 - \$5,356 saved per year at \$0.08/kWh
- Project Costs
 - \$11,117 VFD
- Incentive
 - \$5,559 Incentive
 - Incentive is 50% of the incremental cost as the simple payback is bought down to 1 year.

National Grid 2013 Custom Screening Tool Upstate NY - v 1.0 Report Version - 1.0

Customer Name: VSD Example - Add-On
 Project Description: One older air compressor is replaced with a 100 hp VFD
 Existing Case HV-3 supply fan (15 hp) and RF-1 return fan (15 hp) at constant speed
 Proposed Case Install VSD's to operate the HV-3 and RF-1 at 80% speed.

Utility Contact: Phone Number:
 Program: EI App Number: Example #4
 State: NY Classification: Commercial (< 2 MW)

Time Period	Energy (kWh) Reduction Per Period	Hours Per Period	Average Demand Reduction Per Period
Winter			
December	0	0	0
January	0	0	0
February	0	0	0
Summer			
June	0	0	0
July	0	0	0
August	0	0	0
September	0	0	0

Measure Code:	VSDH	
Measure Description:	Drives on HVAC systems	
Measure Life:	15	
Est Equip Costs	\$11,117	
Est Labor Costs	\$0	
Est Total Cost	\$11,117	
	KW	KWH
Existing Equip Usage	0	175,801
Std Equip Usage	NA	NA
EE Equip Usage	0	108,647
Total Est Annual kWh Savings	66,954	
Average Cost Per kWh	0.08	
Est Annual Energy Cost Savings	\$5,356	
% On Peak Energy Savings	100	
Proposed Incentive	\$5,559	

TRC Method	AddOn		
Existing Age	10	RUL	NA
DFP	NA	A DJEUL	NA
Incr/Full kWh	NA	Incr/Full Cost	NA
Ben Adj	NA	Cost Adj	NA
Oil (Gallons)	0	WasteWater (Gallons)	0
Gas Heating (Therms)	0	Water (Gallons)	0
Gas NonHeating (Therms)	0	Other (\$)	\$0.0
Total NEB \$ Savings	\$0.0		

Pk Sum kW Rd	0.0
kW Years	0	kW Years (A djEUL)	NA
Lifetime MWH	1004.3	Lifetime MWH (A djEUL)	NA
Payback Without Incentive	2.1		
Payback With Proposed Incentive	1.0		

50% of Project Cost

Customer Cost : \$5,559

Step 3: Deliverables

- BC Screening Report (Analysis Report)
- .csv File
- EEM Breakout spreadsheet

Email the Report, .csv and the EEM Breakout SS to your National Grid sales representative for a technical review and the next step, Energy Assessment, Scoping Study, Tech Review or TA Study.

To export the current report and .csv File, while on the screening tool input screen:
Click on <Report>
Click on <Analysis Report>
Click on <Export>


Now the current files, the BC screening report and the .csv file will upload automatically to your C drive file: CustTool_NG/Cust2013_NY_v1 (see the screenshot below).

BC Screening Report - For the report to upload as the file report.htm below you have to view the report while in the screening tool and then it will be the most current file.

.csv File or as it is known in the file below, output.csv will be the current file if you export it from within the screening tool

TIP 4 – If you cut and paste an output.csv file into the CustTool_NG/Cust2013_NY_v1 you can then go to the screening tool and <import> and it will populate the screening tool.

Note: You need to copy and past the two files in order to save the files for each EEM screened.



Step 4 - EEM Breakout Spreadsheet

Enter Screening results onto the spreadsheet.

Note - an example EEM BO spreadsheet will be provided, but feel free to make your own as long as the information is identical.

What is the EEM Breakout spreadsheet?

- It is an EEM Summary for a consistent deliverable
- Tool to calculate common gas and electric EEMs project cost
- A Sales Tool

Inputs:

- 1) Annual Gas and Electric Consumption
- 2) Information from the screening tools, gas and electric.

Gas Screening Tool

Currently the gas screening tool is being revised. If you require the gas screening tool contact your National Grid representative for a copy and training.